

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 03/26Date : 25.03.2026

It is certified that an inspection team headed by Mr. VIKAS KUMAR
TECHNICAL MANAGER (Name of Officers
with designation) from U.P. JAL NIGAM (RURAL) AMBEDKAR NAGAR (Name of
Department/Office) inspected the S.B.S. COLLEGE
MATHIYA, AMBEDKAR NAGAR (Name & Address of
the School) on 24.03.2026 and found that the S.B.S. COLLEGE
MATHIYA, AMBEDKAR NAGAR (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 24.03.2029.



MANAGER
S.B.S.College Mathiya
Ambedkar Nagar

Technical Manager
District Level Water Analysis Laboratory
Signature with Seal : UPJN Ambedkar Nagar
Name : Vikas kumar
Designation : Technical Manager

To

S.B.S. COLLEGE
MATHIYA
AMBEDKAR NAGAR

(Name & Address of the Institution)


Sunil Sharma
Principal
S. B. S. college
Mathiya Ambedkar Nagar



TEST REPORT
DISTRCT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR



ULR NO-TC172172600000088F

Report No- Chemical Test/ 2403202601/2025-2026 Date 25.03.2026 S.No -01 SAMPLE CODE MR2403202601

Customer Details- S.B.S.COLLEGE MATHIYA AMBEDKAR NAGAR

Office Name and Address Office of excutive engineer ,khand karyalay, U.P. Jal Nigam(Rural),Sabun gall,Akbarpur,District-Ambedkar Nagar ,Pin-224122

Ref Letter No & Date S.B.S./70103/512

Basic details of sample

District	AMBEDKAR NAGAR	Block	BHIYAON
Gram Panchayat	MATHIYA	Village	MATHIYA
Habitation	S.B.S.COLLEGE MATHIYA	Location	KHAS
Water Source	R.O.	Sample No.	1
Quantity of Sample	1 L	Date of S.C.	24.03.2026
Receiving Date	24.03.2026	S. Collector	SELF
Sample Depositor	ABHISHEK I VERMA	S.Method	IS 17614 (PART-05)-2021
Analysis Start Date	24.03.2026	Analysis Completion Date	25.03.2026

Environmental Condition

Temperature	25± 3 °C	Relative Humidity	50%±15%
-------------	----------	-------------------	---------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Odour	NA	Agre	Agreeable	Agreeable	IS 3025(Part 05):2018
2	Taste	NA	Agre	Agreeable	Agreeable	IS 3025(Part 8):2023
3	Colour	HU	5.00	5	15	IS 3025(Part 04):2021
4	Ph	NA	7.06	6.50	8.50	IS 3025(Part 11):2022
5	Turbidity	NTU	0.90	1	5	IS 3025(Part 10):2023
6	TDS	mg/L	110.00	500	2000	IS 3025(Part 16):2023
7	Alkalinity	mg/L	40.00	200	600	IS 3025(Part 23):2023
8	Chloride	mg/L	34.00	250	1000	IS 3025(Part 32):2019
9	Hardness	mg/L	60.00	200	600	IS 3025(Part 21):2023
10	Calcium	mg/L	26.92	75	200	IS 3025(Part 40):2024
11	Magnesium	mg/L	14.11	30	100	APHA 24rd Edition -3500 Mg By Calculation Method
12	Sulphate	mg/L	4.65	200	400	IS 3025(Part 24):2022
13	Nitrate	mg/L	0.11	0	45	APHA 24rd EDITION -3500 NO3-B method
14	Fluoride	mg/L	0.02	1	1.5	IS 3025(Part 60):2023
15	Iron	mg/L	0.08	0	1	IS 3025(Part 53):2024

1.Statement of conformity

N/A

2.Reporting opinions and interpretations ISO 17025

N/A

Note:-

- 1.Source is not varified by the laboratory.
2. This Certificate refers only to the particular sample(s) submitted for testing.
3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
4. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
5. Sample will be stored up to 7days (In case of non perishable Items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
Prepared By

Vikas
Authorized Signatory
VIKAS KUMAR
Technician Manager

Laboratory Contact details- Mob-9981490366

**End of Test Report **

Email-eeupjn.cdambedkarnagar@gmail.com

District Level Water Analysis Laboratory
UPJN Ambedkar Nagar



TEST REPORT
DISTRICT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR

(Non NABL
Accredited
parameter)

Report No- Chemical Test/ 2403202601/2025-2026
 Customer Details- S.B.S.COLLEGE MATHIYA AMBEDKAR NAGAR Date 25.03.2026 S.No -01 SAMPLE CODE MR2403202601
 Office Name and Address Office of executive engineer ,khand karyalay, U.P. Jal Nigam(Rural),Sabun gall,Akbarpur,District-Ambedkar Nagar ,Pin-224122
 Ref Letter No & Date S.B.S./70103/512

Basic details of sample			
District	AMBEDKAR NAGAR		
Gram Panchayat	MATHIYA	Block	BHIYAON
Habitation	S.B.S.COLLEGE MATHIYA	Village	MATHIYA
Water Source	R.O.	Location	KHAS
Quantity of Sample	1 L	Sample No.	1
Receiving Date	24.03.2026	Date of S.C.	24.03.2026
Sample Depositor	ABHISHEK I VERMA	S. Collector	SELF
Analysis Start Date	24.03.2026	S.Method	IS 17614 (PART-05)-2021
		Analysis Completion Date	25.03.2026

Environmental Condition			
Temperature	25± 3 °C		
	Relative Humidity	50%±15%	

Technical Data of Analysis						
S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
16	Free Residual Chlorine	mg/L	0.00	0.2	1	IS 3025(Part-26):2004
17	E.coli	H2S Vials	0.00	0	0	H2S Vials
1.Statment of conformity						N/A
2.Reporting opinions and interpretations ISO 17025						N/A

Note:-
 1. Source is not verified by the laboratory.
 2. This Certificate refers only to the particular sample(s) submitted for testing.
 3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 4. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 5. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
Prepared By

Authorized Signatory
 VIKAS KUMAR
 Technical Manager

**End of Test Report **

District Level Water Analysis Laboratory
 UPJN Ambedkar Nagar

MANAGER
 S.B.S.College Mathiya
 Ambedkar Nagar

Sunil Sharma
 Principal
 S. B. S. college
 Mathiya Ambedkar Nagar